

FIRE ALARM INSTRUCTIONS

FOR BUILDING „J“

lodging house Ještědská Street 341, Liberec VIII – Dolní Hanychov

1. Obligations when a fire is detected

Every employee or other person is required to take such action in case of a fire in or near TUL facilities so that the fire is extinguished with available extinguishing agents and spreading of the fire is prevented. If this is not possible, they shall announce the fire in person or by telephone at the local fire alarm point - the reception at building IC.

When making the announcement, you need to say the name of the announcer, the location of the fire and the phone number from which it is being called.



Building manager – mobile 725 869 419
ext. 3302 –IC TUL reception (24 hours a day)
tel. 485 353 302, mobile 724 244 537

2. The Method of Declaring a Fire Alarm





Fire alarm is declared:

By shouting HOŘÍ / FIRE!

3. Obligations of persons after a fire alarm has been declared:

When a fire alarm has been declared, the persons must immediately leave the building and gather in front of it in such a place where they are not an obstacle to the Fire brigade and follow the instructions of a person in charge of evacuation management or the head of the fire brigade.

4. Emergency numbers and other important phone numbers (when calling from a TUL land line, use the prefix “0“):

AMBULANCE		155	Disorders - WATER	840 111 111 601 267 267
POLICE		158	Disorders - ELECTRICITY	800 850 860
FIRE BRIGADE		150	Disorders – GAS	1239
Integrated Rescue System		112		

5. Main power switches and caps:

Water – Basement of the building – gas boiler room to the left of the door, room.no. -01006 – the door designated as „Hlavní uzávěr vody“,

Electricity– button „TOTAL STOP“ to the right of the main door on the 1st floor, room no. 01001 + switchboard in the corridor on the 1st floor to the left of the main entrance „Hlavní vypínač“,

Gas – outside the building on the northern wall of the building, next to the outside chimney body from the boiler room („HUP“)

Date: 20/7/2018	Approved by:	Ing. Vladimír Stach, Bursar	
	Drafted by:	Bc. Věra Strejčková Z-OZO-14/2017	